



Licensing & Accreditation Department

إدارة الترخيص و الاعتماد

License Number	6480	رقم الترخيص	
Establishment Ref. #	1519	1519	رقم مرجع المنشأة
Establishment Name	Al Ameer English School Clinic	عيادة مدرسة الامير الانجليزية	إسم المنشأة
Owner Name	ABDULRAHMAN OBAID KHALFAN MAJID ALMATROOSHI	عبدالرحمن عبيد خلفان ماجد المطروشي	اسم المالك
Establishment Type	Private	خاص	نوع المؤسسة
Emirates	Ajman	عجمان	الأمانة
Classification	School Clinic	عيادة مدرسية	تصنيف المؤسسة
Location	AL JURF - AL JURF	AL JURF - AL JURF	الموقع
Date From	09/09/2024	2024/09/09	من تاريخ
Date To	08/09/2025	2025/09/08	إلى تاريخ
Add On Services			أضف على الخدمات





عرفه لخدمات مكافحة المشرات ARAFA PEST CONTROL SERVICES

AGREEMENT

TO,
AL AMEER ENGLISH SCHOOL
JURF, AJMAN, UAE
PH: 06 7436600

Date : 12/09/2024
Our Ref :APS/983/2024

SUBJECT: - PEST CONTROL FOR AL AMEER ENGLISH SCHOOL

Dear Sir,

Arafa Pest would like to offer you pest control service. We introduce here by our service as a leading company for a pest control service in UAE.

We have our different teams that are specified experienced qualified and super used by a technical engineer and Foreman.

- Unlimited call back service in case of emergency or complaint
- Met to be attending the call in 24 hours

AREA COVERED

AL AMEER ENGLISH SCHOOL – School Compound Inside all area, Class room, Office room, Kitchen, Staff room, Toilet, Rat bait station include.

PRICE SUMMARY

Total Amount* = 4,000/- Dh:s

One year 4 Services

TERMS AND CONDITION

- 1- Electrical & Water facility to be provided by the client
- 2- Payment- One Time.
- 3- Treatment against all kind of Cockroach and Rats
- 4- Treatment Pesticide cockroaches- CIPEKILL EC, Rat- Protect Extruded Rodenticide Blocks
- 5- 5 % VAT Exclude
- 6- One year Agreement (12/09/2024 to 11/09/2025)

Signature
ARAFA PEST CONTROL
AJMAN, UAE
PH : 054 586 7774



Signature
AL AMEER ENGLISH SCHOOL
AJMAN , UAE

Central Laboratories Department
Food Laboratory Section

إدارة المختبرات المركزية
قسم مختبر الأغذية

Test Report

Ref.No	F2504386	Received Date	28/05/2025	Date of Issue	30/05/2025
Client & Sample Details					
Name :	Al Ameer English Sch.				
Source :	Al Ameer English Sch.	Certificate No. :			
Sample :	Drinking Water	Sampling by :	معاذ محمد راشد الشحي		
Description :	GIRLS SECTION	Packaging Type:	Plastic Bottle		
Brand :	NO Brand	Origin :	UAE		
Net wt/volume per unit :	/	Prod.Date :			
Reason of Analysis :	School Survey	Exp.Date :			
Remarks :	Qty:-01plastic+01glass=02pcs / Condition:-Room Temp(22.3°C) / NO Barcode Number / Time:-09:00AM				
Test Result					
Parameter	Method	Result	Unit	Ref. Limit	Remarks
PHYSICAL RESULTS					
General appearance	Analysis Start Date	28/05/2025	Analysis End Date	28/05/2025	
Label and Packaging	U.A.E std 9 , 150	/			
Organoleptic Evaluation		Unobjectionable			
Satisfactory					
MICROBIOLOGICAL					
E.coli	*APHA 9223 B/IDEXX manual	Not Detected	/100 ml	Not Detected (I)	
Pseudomonas aeruginosa	APHA 9213 G / IDEXX manual	Not Detected	/250 ml	Not Detected (I)	
Total Coliforms	*APHA 9223 B/IDEXX manual	Not Detected	/100 ml	Not Detected (I)	
Satisfactory					
CHEMICAL RESULTS					
Free Chlorine	Analysis Start Date	28/05/2025	Analysis End Date	29/05/2025	
Conductivity	APHA 2510 B/EC meter	208	us/cm		
TDS	APHA 2510 B/EC meter	123	mg/L	(100-1000)	
pH	APHA 4500 H+ B/pH meter	8.5	pH Unit	6.5 - 8.5	
Satisfactory					
Final Result	Investigated Parameters are Compliant with Regulations/Standards				
General Comments	Micro Results: UAE.S 1016:2017.CHEM.Result :UAE.S GSO 149:2021				

حكومة عجمان
دائرة البلدية والتخطيط
Government Of Ajman
Municipality & Planning Department
إدارة المختبرات المركزية
Central Laboratories Dept.
النتائج متوافقة مع اللوائح / المعايير
Investigated Parameters are
Compliant with Regulations / standards



Central Laboratories Department
Food Laboratory Section

إدارة المختبرات المركزية
قسم مختبر الأغذية

Test Report

Ref.No	F2504387	Received Date	28/05/2025	Date of Issue	30/05/2025
Client & Sample Details					
Name :	Al Ameer English Sch.				
Source :	Al Ameer English Sch.	Certificate No. :			
Sample :	Drinking Water	Sampling by :	معاد محمد راشد الشحي		
Description :	BOYS SECTION	Packaging Type:	Plastic Bottle		
Brand :	NO Brand	Origin :	UAE		
Net wt/volume per unit :	/	Prod.Date :			
Reason of Analysis :	School Survey	Exp.Date :			
Remarks :	Qty:-01plastic+01glass=02pcs / Condition:-Room Temp(22.3°C) / NO Barcode Number / Time:-09:00AM				
Test Result					
Parameter	Method	Result	Unit	Ref. Limit	Remarks
PHYSICAL RESULTS		Analysis Start Date	28/05/2025	Analysis End Date	28/05/2025
General appearance		Satisfactory			
Label and Packaging	U.A.E std 9 , 150	/			
Organoleptic Evaluation		Unobjectionable			
Satisfactory					
MICROBIOLOGICAL		Analysis Start Date	28/05/2025	Analysis End Date	29/05/2025
E.coli	*APHA 9223 B/IDEXX manual	Not Detected	/100 ml	Not Detected (I)	
Pseudomonas aeruginosa	APHA 9213 G / IDEXX manual	Not Detected	/250 ml	Not Detected (I)	
Total Coliforms	*APHA 9223 B/IDEXX manual	Not Detected	/100 ml	Not Detected (I)	
Satisfactory					
CHEMICAL RESULTS		Analysis Start Date	28/05/2025	Analysis End Date	29/05/2025
Free Chlorine		< 0.2	ppm		
Conductivity	APHA 2510 B/EC meter	218	us/cm		
TDS	APHA 2510 B/EC meter	131	mg/L	(100-1000)	
pH	APHA 4500 H+ B/pH meter	8.3	pH Unit	6.5 - 8.5	
Satisfactory					
Final Result	Investigated Parameters are Compliant with Regulations/Standards				
General Comments	Micro Results: UAE.S 1016:2017.CHEM.Result :UAE.S GSO 149:2021				