

ANALYSIS REPORT

SAMPLE INFORMATION

Ref No.	56.24E	Submit Date	12/03/2024
Sample Desc.	Filter water	Approval.Date	14/03/2024
Reason	Personal Request	Prod.Date	-
FIRS	-	Expiry Date	-
Source	New Indian School	Net Volume	-
Brand	-	Origin	UAQ, UAE

PHYSICAL RESULT

Parameter	Result
General appearance	Satisfactory
Label and packaging	Not Included

MICROBIOLOGICAL EXAMINATION

Parameter	Test Method	Result	Unit
<i>Pseudomonas aeruginosa</i>	Conventional Plate	Not Detected	CFU/250ml
<i>E.coli</i>	Idexx- Quanti Tray	Not Detected	MPN/100ml
Coliforms	Idexx- Quanti Tray	Not Detected	MPN/100ml

CHEMICAL EXAMINATION

Parameter	Test Method	Result	Unit
pH Value at 25°C	Multimeter Probe	07.42	n/a
Conductivity	Multimeter Probe	78.20	µS/cm
Total Dissolved Solids	Multimeter Probe	37.70	mg/liter
NaCl	Multimeter Probe	00.04	%

GENERAL COMMENTS – SATISFACTORY

Final Conclusion : The Tested Parameters Are Compliant With GSO Regulations/Standards for Drinking Water.

Note :

- The above results are related to the sample received by the Laboratory.
- This report shall not be reproduced without approval from Laboratory.

Approved By:

